



**NOTES**

**IMPROPER SITE PREPARATION WILL RESULT IN DAMAGE TO THE TANK**

1. ACCESS ROUTE FOR TRUCK REQUIRES 14-FT VERTICAL CLEARANCE.
2. KEEP THE WALLS OF EXCAVATION STRAIGHT AS POSSIBLE.
3. LEVEL THE BOTTOM OF EXCAVATION.
4. USE OF WASHED SAND OR WASHED GRAVEL FOR LEVEL CUSHION UNDER TANK. USE OF ANY OTHER MATERIAL WILL VOID WARRANTY OF TANK.

**SITE PREPARATION GUIDELINES**



**HILL COUNTRY**  
CONCRETE PRODUCTS, INC.

PO Box 357  
Kyle, Texas 78640  
512.268.9711  
Austin Line 512.476.5838  
Fax 512.268.0215  
hillcountryconcrete.com